


| | | | |
|--|--|--|---|
|  | <p style="text-align: center;">Clarendon County Procurement</p> <p style="text-align: center;">REQUEST FOR PROPOSAL</p> <p style="text-align: center;">ADDENDUM #1</p> | <p>Solicitation Number & Project Name:</p> <p>Buyer:</p> | <p>REQUEST FOR PROPOSALS- CONSTRUCTION OF ADA COMPLIANT RESTROOMS</p> <p>Tamika Malone, Procurement Director E-Mail procurement@clarendoncountygov.org</p> |
|--|--|--|---|

August 19, 2014

The purpose of **ADDENDUM #1** is to provide:

1. Drainage requirements; which were inadvertently left off the plumbing plan.

Contractor shall install one (1) each cast iron floor drain in each restroom. Floor drain shall tie into existing sewer system.

2. Provide answers to written questions received.

Q1: The plans are for a site Built 8" CMU block building with a 2X8 wood framed chase. Would a pre-fabricated building of engineered 4" CMU block with CMU walled chase be considered?

A1: Yes, engineered 4" CMU would be acceptable.

Q2: The plans provided do not allow for a separate chase, which leaves plumbing and fixtures exposed to vandalism. Would a slight re-design be considered?

A2: Yes, separate chase with slight re-design would be acceptable.

Q3: Is there an approximate budget for the restroom building only?

A3: The approximate budget for restroom building only is 24,000

All other solicitation requirements remain the same. Please remember to acknowledge this **Addendum#1 on page 2** of original solicitation.

Please address all questions in writing to procurement@clarendoncountygov.org